

4.0 CAPACITY ASSESSMENT

- The design capacity of the sewage works is stated in the Certificate of Approval as being 960 cubic metres. Due to the large amounts of diesel flowing into the diesel recovery lagoon, the diesel recovery system was started during the week of April 15, 1999. At the time of start up, approximately 1,200 litres of product was removed from the waste oil recovery tank. Approximately 5,783 litres of product was collected between April 15 and May 4. An additional 3,812 litres of product was collected between May 4 and June 2. The total volume of product collected in 1999 as of June 2 was 10,759 litres..

5.0 SAMPLING REQUIREMENTS

- The Certificate of Approval requires the owner to collect a grab sample of the effluent once each month at stream A, effluent from the discharge control gate. Effluent monitoring is being conduct by the owner in accordance with the Certificate of Approval.

6.0 REPORTING REQUIREMENTS

- The owner is required to immediately report all spills of polluting substances into the environment as specified in the Certificate of Approval.

7.0 FLOW MEASUREMENT

- Flow measurement is not required by the Certificate of Approval.

8.0 MINISTRY SAMPLE RESULTS

- Were Ministry samples collected during the inspection ? Yes

Comment: A grab sample was collected for analyses of parameters specified in the Certificate of Approval. One sample container broke in transit and therefore only the oil and grease parameter was analysed for, the result of which was 5.5 milligrams per litre. This result is in compliance with the Certificate of Approval limit of 15 milligrams per litre.

9.0 REVIEW OF OUTSTANDING ISSUES

- There are no outstanding issues related to this facility.